



Fire Protection

VdS • P.O. Box 103753 • 50477 Köln, Germany

FOGTEC Brandschutz GmbH & CO. KG
Herr Laibach
Schanzenstrasse 19A

51063 Köln

Office address
VdS Schadenverhütung
Brandschutz
Amsterdamer Str. 172
50735 Köln, Germany

Your contact
Christian Kopp
ckopp@vds.de
Phone: +49 221 77 66 - 598
Fax: +49 221 77 66 - 308
www.vds.de

Your reference

Our reference
Reh/Kop

Date
03.09.2012

Dear Mr. Laibach,

We are glad to confirm that your High Pressure Water Mist System is presently subject to a running approval procedure at VdS.

Successful fire and extinguishing tests have been carried out for the following applications:

- OH1 Office
- OH1 False Floor, False Ceiling

Please note that this letter only documents the current status of the running approval procedure. In order for you to be granted the final VdS approval, the following steps will have to be carried out:

- Testing of all relevant components of the system
- Examination of the planning and installation manuals for the above mentioned applications.

This letter is valid until 31.12.2012 and supersedes all prior confirmations.

Best regards,

i.V. Norbert Reinhard

i.A. Christian Kopp